

Jac

Georgia Department of Natural Resources

**Environmental Protection Division • Air Protection Branch
4244 International Parkway • Suite 120 • Atlanta • Georgia 30354**

404/363-7000 • Fax: 404/363-7100

Noel Holcomb, Commissioner

Carol A. Couch, Ph. D., Director

NOV 09 2004

Merry Norman
Invista, S.á.r.l.
110 Voyles Road
Athens, Georgia 30601-3907

Re: Application Number 15624
Invista, S.á.r.l., Athens, Clarke County

Dear Ms. Norman:

Enclosed please find Air Quality Permit No. 2282-059-0038-B-01-1 for the operation of a 400 HP Cleaver-Brooks boiler at Invista, S.á.r.l. in Athens, Georgia.


Note that any future modifications that might affect potential emissions from your facility will require review and possible permitting through this office.

The following types of correspondence should be sent to the Division personnel indicated:

- Testing: James Capp – Program Manager, Industrial Source Monitoring Program
- Monitoring and Compliance (reports): Bob Bishop – Northeast District Manager, 745 Gaines School Road, Athens, GA 30605.

Thank you for your cooperation. If you have any questions or need more information, please contact me at (404) 363-7036 or via email at irene_abraham@mail.dnr.state.ga.us.

Sincerely,




Irene K. Abraham
Environmental Engineer
Stationary Source Permitting Program

Enclosure

c: Ender Serefli
Northeast District



State of Georgia
Department of Natural Resources
Environmental Protection Division
Air Protection Branch



AMENDMENT TO AIR QUALITY PERMIT

Permit Amendment No.
2282-059-0038-B-01-1

Effective Date of Amendment

NOV 09 2004

In accordance with The Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq and the Rules, Chapter 391-3-1, adopted pursuant to or in effect under that Act, Permit No. 2282-059-0038-B-01-0 issued on June 8, 2004 to:

Facility Name: Invista, S.á.r.l

Mailing Address: 110 Voyles Road
Athens, Georgia 30601-3907

Facility Location: 110 Voyles Road
Athens, Georgia 30601-3907 (Clarke County)

for the following: Operation of heather yarn manufacturing facilities including process fume control system.

is hereby amended as follows: To allow the operation of one (1) Cleaver-Brooks Model CB Package Boiler with a rated capacity of 400 horsepower.

Reason for Amendment: 15624 dated September 7, 2004.

This Permit is further subject to and conditioned upon the terms, conditions, limitations, standards, or schedules contained in or specified on the attached 1 page(s), which page is part of this Amendment.

This Permit Amendment is effective from the date first above written and is hereby made a part of Permit No. 2282-059-0038-B-01-0 and compliance herewith is hereby ordered. Except as amended hereby, the above referenced Permit remains in full force and effect.

Director
Environmental Protection Division

**State of Georgia
Department of Natural Resources
Environmental Protection Division**

**Permit Amendment No.
2282-059-0038-B-01-1**

Page 1 of 1

2.1 Equipment SIP Rule Standards

Georgia Rule (d) – Fuel-burning Equipment

- 2.1.1 The Permittee shall not cause, let, suffer, permit, or allow the emissions of fly ash and/or other particulate matter from the Boiler No. 1 (Source Code BR01) in amounts equal to or exceeding 0.5 pounds per million BTU heat input.
[391-3-1-.02(2)(d)2(i)]
- 2.1.2 The Permittee shall not cause, let, suffer, permit or allow emissions from the Boiler No. 1, 2, 3 or 4 (Source Codes BR1, BR2, BR3, or BR4) the opacity of which is equal to or greater than twenty (20) percent except for one six minute period per hour of not more than twenty-seven (27) percent opacity.
[391-3-1-.02(2)(d)3]